

Zertifikat Certificate



Zertifikat Nr. Certificate No.
R 50135596

Blatt Page
0001

Ihr Zeichen Client Reference
KTN080401-1

Unser Zeichen Our Reference
ZO-SHY- 12307073 001

Ausstellungsdatum
20.08.2008

Date of Issue
(day/mo/yr)

Genehmigungsinhaber License Holder
KITANI ELECTRIC CO., LTD.
1-13-3 Nagaokagu-machi
Hirakata-shi, Osaka
573-0102 JAPAN

Fertigungsstätte Manufacturing Plant
KITANI ELECTRIC CO., LTD.
Sha Tou Industrial Park
Dong Da Road
Changan Zhem, Dong Guan City
Guang Dong Province 523861
P.R. China

Prüfzeichen Test Mark



Geprüft nach Tested acc. to

DIN V VDE V 0126-5/05.08

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Anschlussdose Junction Box for Photovoltaic-Systems

Type Designation : KTN-PVBFA4T I-II III IV-V-VI 5
(I, II, III, IV, V, VI = see Appendix 1) 2

Rated Voltage : DC 1000V
Rated Current : max. 30A
Overvoltage Category : III
Pollution Degree : 3
IP-code : IP65
Ambient Temperature : -40°C to +90°C
Insulation System : Reinforced insulation
Use : Outdoor application in class II equipment

Remark: The labelling requirements acc. to EU Directive 2001/95 have to be observed for distribution within the EEA.

7

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.



Zertifizierungsstelle

TÜV Rheinland Product Safety GmbH, Am Grauen Stein, D-51105 Köln

Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com

Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Dipl.-Ing. M. Geiser